

GRUMMAN ENGINEERING, LLC

Consulting Civil Engineers
20 Knight Street
Norwalk, Connecticut 06851
(203) 853-3833
Fax: (203) 286-5057

February 22, 2022

Ralph Kolb, P.E.
Wastewater Systems Manager
Water Pollution Control Authority
15 South Smith Street
Norwalk, CT 06855

Re: Wastewater Flow Computations
162 Strawberry Hill Avenue, Norwalk
GE Project 22-5504

Per Ct. Department of Public Health – Public Health Code:

Proposed Conditions Daily Flowrate:


Lot 1A – Proposed 4-Bedroom Dwelling

3 Bedrooms x 150 GPD + 1 Bedroom x 75 GPD = 525 GPD

Lot 1B – Proposed 4-Bedroom Dwelling

3 Bedrooms x 150 GPD + 1 Bedroom x 75 GPD = 525 GPD

Respectfully submitted,


Dean E. Martin, P.E.

