

MEMORANDUM

TO: Elizabeth A.B. Suchy, Carmody Torrance Sandak & Hennessey LLP

FROM: Wilber Giron, Permit Engineer, Department of Public Works

CC: Ralph Kolb, Sr. Environmental Engineer, Water Pollution Control Authority
William Ireland, Chief Building Official, Code Enforcement
Christine Cardascia, Junior Engineer, Department of Public Works

DATE: April 13, 2022

REASON: 32 Weed Avenue (D-B-L: 5-55-11)
Proposed Private School

The Water Pollution Control Authority (WPCA) for the City of Norwalk has completed its review of the March 14, 2022 application, including engineering drawings prepared by Partners for Architecture, LLC for the proposed private school to be located at 32 Weed Avenue.

WPCA has the following comments:

1. Please calculate and provide existing and proposed daily wastewater flows (average and maximum daily flow and peak flow rate) for the site. Include description of discharge source and any potential contaminants. Sewage flow calculations should be based on TR-16 "Guides for the Design of Wastewater Treatment Works," Connecticut Department of Public Health – Public Health Code, or other good engineering practice standards
2. Please confirm if a modification to the private sanitary sewer pump station (onsite) or force main is proposed.
3. Submit the size and quantity of existing and proposed water meter(s) for the site.
4. Please confirm if any modifications are proposed to the kitchen. If applicable, submit the following:
 - a. Identify the size and location of grease recovery units
 - b. Include grease recovery unit details (cut sheets/shop drawings)
 - c. Include floor plumbing and grease waste lines and invert elevations on drawings
 - d. Provide equipment schedule on drawings
5. Please confirm if storm drain systems within covered parking areas are proposed.
6. Uncovered parking areas shall not be permitted to discharge into the sanitary sewer.
7. Please note the swimming pool wastewater discharge must comply with the Connecticut Department of Energy and Environmental Protection Miscellaneous Industrial Users (MIU) General Permit.

<input checked="" type="checkbox"/> Comments Attached (see above)
<input type="checkbox"/> Approved